

## DECLARATION

FlexiForce Group BV in Barneveld, the Netherlands, declares that:

**Tecsedo SA**  
Repr. Mr M. Tognelli  
Zona Industriale 1  
6807 Taverne  
Switzerland

Hanzeweg 25,  
3771 NG Barneveld  
P.O. Box 37,  
3770 AA Barneveld  
The Netherlands

**T** +31 (0)342427777  
**F** +31 (0)342427723  
**T** +31 (0)342427722 (dir)  
**E** frgo@flexiforce.nl  
**W** www.flexiforce.com

has joined the Initial Type Testing in accordance to the standard EN 13241-1 in combination with the below mentioned hardware and operators.

ITT number FlexiForce: 0402-CPD-407001 issued by SP-Institute, Sweden.

### Hardware Flexi-Force BV

FlexiForce® industrial hardware components

### Operators:

Marantec  
MFZ  
Liftmaster Professional/Chamberlain  
Faac Spa  
Nice Spa  
Dalmatic A/S  
Ovitor OY  
Becker GmbH  
Ditec  
Mtec  
BFT  
Ellard

*(all operators with the same construction but sold under different brand names are also a part of this type of test report.)*

### Obtained results:

Wind load	Class :	3
Air permeability	Class :	3
Resistance to water penetration	Class :	1
Thermal resistance without windows and pass door	U door:	0.8 W/(m <sup>2</sup> /K)
Thermal resistance with windows and pass door	U door:	1.0 W/(m <sup>2</sup> /K)

All tests are supervised and approved by Swedish National Testing and Research Institute in Sweden.

Barneveld, 18 June 2008  
Flexi-Force Group B.V.  
Frank Goedhart